



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Mark Rampado
Amherst CSD
55 Kings Hwy
Amherst, NY 14226**

8/28/2017

Phone: (716) 362-8355
Fax: (716) 836-4972

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/21/2017. The results are tabulated on the attached data pages for the following client designated project:

Amherst High School

The reference number for these samples is EMSL Order #011706763. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011706763

CustomerID: AMHE50

CustomerPO: 18-00101

ProjectID:

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 08/21/17 9:10 AM

Project: **Amherst High School****Analytical Results**

Client Sample Description 030 **Collected:** 8/15/2017 **Lab ID:** 011706763-0001
 Room 317 6:52:00 AM

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.7	1.00	µg/L	8/25/2017	KB	8/25/2017	KB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)