



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Mark Rampado

Amherst CSD

55 Kings Hwy

Amherst, NY 14226

Phone: (716) 362-8355

Fax: (716) 836-4972

3/21/2017

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/13/2017. The results are tabulated on the attached data pages for the following client designated project:

**Project ID: PO Box 17-00954 NY State Component School Dist.
Amherst Middle School**

The reference number for these samples is EMSL Order #011701882. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 3-AMS-A
 South-Gym-Boys-Coaches-Office
Collected: 2/23/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.01	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 3-AMS-B
 South-Gym-Boys-Coaches-Office
Collected: 2/23/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.96	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 12-AMS-A
 Room134
Collected: 2/23/2017 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.6	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 12-AMS-B
 Room134
Collected: 2/23/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 13-AMS-A
 Room132
Collected: 2/23/2017 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	24.6	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 13-AMS-B
 Room132
Collected: 2/23/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.42	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 15-AMS-A
 Room124
Collected: 2/23/2017 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	79.7	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 15-AMS-B
Room124
Collected: 2/23/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	47.5	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 18-AMS-A
Boys-Nprth-Gm-Coaches-Office
Collected: 2/23/2017 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.5	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 18-AMS-B
Boys-Nprth-Gm-Coaches-Office
Collected: 2/23/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.13	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 21-AMS-A
Girls-North-Gym-Coaches-Office
Collected: 2/23/2017 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.37	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 21-AMS-B
Girls-North-Gym-Coaches-Office
Collected: 2/23/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 52-AMS-A
Boys-Bathrrom-From-Left-E
Collected: 2/23/2017 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.3	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 52-AMS-B
Boys-Bathrrom-From-Left-E
Collected: 2/23/2017 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.09	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 53-AMS-A
 Girls-Bathroom-From-Left-E
Collected: 2/23/2017 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	74.9	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 53-AMS-B
 Girls-Bathroom-From-Left-E
Collected: 2/23/2017 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.0	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 58-AMS-A
 Room115-Right
Collected: 2/23/2017 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.4	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 58-AMS-B
 Room115-Right
Collected: 2/23/2017 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.80	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 60-AMS-A
 Room111-Right
Collected: 2/23/2017 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.99	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 60-AMS-B
 Room111-Right
Collected: 2/23/2017 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.58	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 61-AMS-A
 Room111-Left
Collected: 2/23/2017 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.5	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 61-AMS-B
Room111-Left
Collected: 2/23/2017 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.69	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 75-AMS-A
149-South
Collected: 2/23/2017 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	24.3	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 75-AMS-B
149-South
Collected: 2/23/2017 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 79-AMS-A
149-East-Right
Collected: 2/23/2017 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.14	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 79-AMS-B
149-East-Right
Collected: 2/23/2017 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 93-AMS-A
255-Hallway
Collected: 2/23/2017 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.5	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 93-AMS-B
255-Hallway
Collected: 2/23/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.39	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 95-AMS-A
249-Hallway
Collected: 2/23/2017 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.1	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 95-AMS-B
249-Hallway
Collected: 2/23/2017 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.32	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 101-AMS-A
D.O.-Janitorial-Closet
Collected: 2/23/2017 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 101-AMS-B
D.O.-Janitorial-Closet
Collected: 2/23/2017 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 103-AMS-A
D.O.-Womens-B-Bathroom-From-Left
Collected: 2/23/2017 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.2	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 103-AMS-B
D.O.-Womens-B-Bathroom-From-Left
Collected: 2/23/2017 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.43	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 114-AMS-A
Girls-Bathroom-From-Left-A
Collected: 2/23/2017 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	921	10.0	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 114-AMS-B
 Girls-Bathroom-From-Left-A
Collected: 2/23/2017 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	37.2	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 124-AMS-A
 203-Backroom
Collected: 2/23/2017 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	110	5.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 124-AMS-B
 203-Backroom
Collected: 2/23/2017 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	31.7	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 126-AMS-A
 201-Backroom
Collected: 2/23/2017 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	64.4	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 126-AMS-B
 201-Backroom
Collected: 2/23/2017 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.12	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 127-AMS-A
 202-Backroom
Collected: 2/23/2017 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.0	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 127-AMS-B
 202-Backroom
Collected: 2/23/2017 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.94	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 129-AMS-A
204-Backroom
Collected: 2/23/2017 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	51.3	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 129-AMS-B
204-Backroom
Collected: 2/23/2017 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 130-AMS-A
206-Backroom
Collected: 2/23/2017 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	38.4	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 130-AMS-B
206-Backroom
Collected: 2/23/2017 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.90	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 131-AMS-A
Boys-Bathroom-From-Left-A
Collected: 2/23/2017 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	36.2	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 131-AMS-B
Boys-Bathroom-From-Left-A
Collected: 2/23/2017 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.81	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 135-AMS-A
Girls-Bathroom-From-Left-B
Collected: 2/23/2017 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.4	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 135-AMS-B
 Girls-Bathroom-From-Left-B
Collected: 2/23/2017 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.12	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 136-AMS-A
 Girls-Bathroom-From-Left-C
Collected: 2/23/2017 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.63	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 136-AMS-B
 Girls-Bathroom-From-Left-C
Collected: 2/23/2017 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 139-AMS-A
 218-From-Main-Door-C
Collected: 2/23/2017 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.9	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 139-AMS-B
 218-From-Main-Door-C
Collected: 2/23/2017 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.31	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 142-AMS-A
 214-Near-Window
Collected: 2/23/2017 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.97	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 142-AMS-B
 214-Near-Window
Collected: 2/23/2017 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.41	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 147-AMS-A
 212-From-Main-Door-D **Collected:** 2/23/2017 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.6	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 147-AMS-B
 212-From-Main-Door-D **Collected:** 2/23/2017 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.87	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 149-AMS-A
 210-From-Main-Door-B **Collected:** 2/23/2017 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.7	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 149-AMS-B
 210-From-Main-Door-B **Collected:** 2/23/2017 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.08	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 150-AMS-A
 210-From-Main-Door-C **Collected:** 2/23/2017 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	28.9	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 150-AMS-B
 210-From-Main-Door-C **Collected:** 2/23/2017 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	39.1	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 151-AMS-A
 210-From-Main-Door-D **Collected:** 2/23/2017 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.13	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 151-AMS-B
210-From-Main-Door-D **Collected:** 2/23/2017 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.85	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 159-AMS-A
Kitchen-Near-Breaker-Panel **Collected:** 2/23/2017 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.5	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 159-AMS-B
Kitchen-Near-Breaker-Panel **Collected:** 2/23/2017 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 160-AMS-A
Dishwasher-Room **Collected:** 2/23/2017 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.06	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 160-AMS-B
Dishwasher-Room **Collected:** 2/23/2017 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.97	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 163-AMS-A
Old-Garage **Collected:** 2/23/2017 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.4	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 163-AMS-B
Old-Garage **Collected:** 2/23/2017 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	28.3	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 165-AMS-A
 Ext.-Near-Garage-Door-#22 **Collected:** 2/23/2017 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.59	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 165-AMS-B
 Ext.-Near-Garage-Door-#22 **Collected:** 2/23/2017 **Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 167-AMS-A
 Ext.-Near-Room106 **Collected:** 2/23/2017 **Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	94.5	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 167-AMS-B
 Ext.-Near-Room106 **Collected:** 2/23/2017 **Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.9	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 168-AMS-A
 Ext.-Near-Principal's-Office **Collected:** 2/23/2017 **Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.4	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 168-AMS-B
 Ext.-Near-Principal's-Office **Collected:** 2/23/2017 **Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 169-AMS-A
 Ext.Between-Rooms127&131 **Collected:** 2/23/2017 **Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	125	5.00	µg/L	3/16/2017	AE	3/16/2017	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	011701882
CustomerID:	AMHE50
CustomerPO:	17-00954
ProjectID:	PO Box 17-00954

Attn: **Mark Rampado**
Amherst CSD
55 Kings Hwy
Amherst, NY 14226

Phone: (716) 362-8355
 Fax: (716) 836-4972
 Received: 03/13/17 9:30 AM

Project: **Amherst Middle School****Analytical Results**

Client Sample Description 169-AMS-B **Collected:** 2/23/2017 **Lab ID:** 0078
 Ext.Between-Rooms127&131

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.17	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 170-AMS-A **Collected:** 2/23/2017 **Lab ID:** 0079
 Ext.Between-Rooms143&147

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	53.8	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Client Sample Description 170-AMS-B **Collected:** 2/23/2017 **Lab ID:** 0080
 Ext.Between-Rooms143&147

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.28	1.00	µg/L	3/16/2017	AE	3/16/2017	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)