



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Mark Rampado**

**Amherst CSD**

**55 Kings Hwy**

**Amherst, NY 14226**

Phone: (716) 362-8355

Fax: (716) 836-4972

8/28/2017

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/21/2017. The results are tabulated on the attached data pages for the following client designated project:

**Windermere Elementary**

The reference number for these samples is EMSL Order #011706761. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011706761

CustomerID: AMHE50

CustomerPO: 18-00101

ProjectID:

Attn: **Mark Rampado**  
**Amherst CSD**  
**55 Kings Hwy**  
**Amherst, NY 14226**

Phone: (716) 362-8355  
 Fax: (716) 836-4972  
 Received: 08/21/17 9:10 AM

Project: **Windermere Elementary****Analytical Results**

**Client Sample Description** WE44  
Room 106  
**Collected:** 8/14/2017  
**Lab ID:** 011706761-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	25.5	1.00	µg/L	8/25/2017	KB	8/25/2017	KB

**Client Sample Description** WE46  
Romo 109  
**Collected:** 8/14/2017  
**Lab ID:** 011706761-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1280	20.0	µg/L	8/25/2017	AE	8/28/2017	SM

**Client Sample Description** WE123  
Room 210  
**Collected:** 8/14/2017  
**Lab ID:** 011706761-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	457	10.0	µg/L	8/25/2017	KB	8/25/2017	KB

**Client Sample Description** WE104  
Room 227  
**Collected:** 8/14/2017  
**Lab ID:** 011706761-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	33.0	1.00	µg/L	8/25/2017	KB	8/25/2017	KB

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit  
 RL - Reporting Limit (Analytical)